

CERTIFICATE

Certificate holder	TiSUN GmbH Stockach 100 6306 Söll AUSTRIA
Production facility	Söll
Product	Solar collectors
Type, Model	PFM-S 2.01 m ²
Testing basis	DIN EN 12975-1:2011-01 DIN EN ISO 9806:2014-03 Specific CEN KEYMARK Scheme Rules for Solar Thermal Products version 21.00 (2013-10)

Mark of conformity

Registration No.	011-7S2393 F
Valid until	2019-09-30
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

ANNEX

Page 1 of 1

Certificate 011-7S2393 F dated 2014-10-09

Technical Data See data sheet, part of the test report of 2014-09-25

Note(s):

- The freeze resistance test according to DIN EN ISO 9806, clause 15 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.

**Testing laboratory/
Inspection body**

Universität Stuttgart
Institut für Thermodynamik und
Wärmetechnik
Pfaffenwaldring 6
70569 Stuttgart
GERMANY

Test report(s) No. 14COL1214, No. 14COL1216Q dated 2014-09-25

